



This document is the translation of the French certificate n°17-01364-1 L on the July, 02nd 2018 delivered by IFTH.

MATERIAL REACTION TO FIRE CLASSIFICATION CERTIFICATE

prepared in compliance with amended 5 of the French Home Office Regulation
dated November 21st, 2002 (Official Gazette dated December 31, 2002)

Delivered as an extension of certificate n° 17-01364 L, valid until June, 02nd 2022 expiration date of the first PV

CERTIFICATE N°17-01364-1 L

And 0 appendices of 0 page

MATERIAL presented by :

AMBIENTA srl
VIA DONIZETTI 109 - AREA GELLER D1/A
24030 BREMBATE SOPRA
ITALIE

TRADE NAME :

Farfalla
9137 FARFALLA

BRIEF DESCRIPTION :

100% Inherent flame retardant Trevira CS polyester fabric
Measured surface weight : Product issued of a range from around 40 to 80 g/m²
Measured thickness : Product issued of a range from around 0.1 to 0.2 mm
Colours : various

TEST REPORT :

N°17-01364 E1 - V1 on the June, 02nd 2017

TESTS :

Electrical burner test
Flame persistence test
Dripping test.

CLASSIFICATION :

M 1

Classification valid on the face of use only, for any application with the exception of the stuffed seats regulated by the article AM18 for buildings receiving public

CLASSIFICATION DURATION (article 5 of appendix 2): unlimited unless otherwise specified

given the criteria resulting from the tests described in the enclosed test report.

The classification indicated does not mean that materials marketed comply with the test samples and must not be considered as a qualification certificate as defined by French law article L.433-3 n°2016-301 dated March 14th, 2016.

N.B.: Only integral copies of this document may be made by photocopying the classification report and/or the classification report and enclosed test report.

Issued in Lyon, France, on the July, 02nd 2018

Sophie GUINAMAND
Engineer Tests and Trials

Jean-Marc ORAISON
In charge of Fire Regulation